



NOTES:

1. SUCCESSIVE TAPS INTO THE WATER MAIN SHALL BE A MINIMUM OF 18" ON CENTER.
2. ALL SERVICES REQUIRE 36" MINIMUM COVER AT ALL POINTS ALONG SERVICE.
3. 1"Ø SERVICES REQUIRE A 2" MINIMUM I.D. CASING PIPE. CASING PIPE SHALL BE SCHEDULE 40 PVC.
4. TRACE WIRE TO BE INSTALLED AS PER THIS DETAIL.
5. SERVICE SADDLE SHALL BE PER QUALIFIED PRODUCTS LIST.
6. 1" POLYETHYLENE TUBING SHALL BE PER QUALIFIED PRODUCTS LIST.
7. METERS SHALL BE LOCATED IMMEDIATELY OUTSIDE THE PROPERTY LINE IN THE RIGHT-OF-WAY UNLESS OTHERWISE DIRECTED BY SLWSD (SEE DETAIL SLW-01B).



**MINIMUM CONSTRUCTION STANDARDS FOR
ST. LUCIE WEST SERVICES DISTRICT**
450 SW UTILITY DRIVE,
PORT SAINT LUCIE, FL 34986
PHONE: (772) 340-0220

**RESIDENTIAL WATER
SERVICE CONNECTION**

DETAIL: SLW-01A

DATE: 03/2020

SCALE: N.T.S.

SHEET: 1 OF 2