



NOTES:

1. THE ENGINEER-OF-RECORD SHALL SIZE THE PIPE, FITTINGS, VALVES AND APPURTENANCES; THE MINIMUM SHALL BE 2" UP TO THE ANGLE VALVE.
2. BOTH RISERS SHALL BE BRASS OR TYPE "K" COPPER TUBING (HARD DRAWN) WITH COPPER/BRASS THREADED FITTINGS AND ADAPTERS.
3. ADDITIONAL SUPPORT SHALL BE PROVIDED AS NECESSARY TO SECURELY SUPPORT THE BACK FLOW PREVENTION ASSEMBLY.
4. VALVE, SADDLE AND APPURTENANCES SHALL BE PER THE QUALIFIED PRODUCTS LIST.
5. ALL METERS SHALL BE PURCHASED FROM AND INSTALLED BY SLWSD.
6. SLWSD "POINT OF SERVICE" VALVE SHALL BE THE CLOSEST VALVE TO PROPERTY LINE.



**MINIMUM CONSTRUCTION STANDARDS FOR
ST. LUCIE WEST SERVICES DISTRICT**
450 SW UTILITY DRIVE,
PORT SAINT LUCIE, FL 34986
PHONE: (772) 340-0220

**COMMERCIAL WATER
SERVICE CONNECTION**

| |
|------------------------|
| DETAIL: SLW-02A |
| DATE: 03/2020 |
| SCALE: N.T.S. |
| SHEET: 1 OF 2 |