



**NOTES:**

1. SAMPLING POINTS SHALL BE LOCATED AS SHOWN ON PLANS APPROVED BY SLWSD AND AS REQUIRED BY FLORIDA DEPARTMENT OF ENVIRONMENTAL PROTECTION.
2. THE EXCAVATED HOLE FOR THIS INSTALLATION SHALL BE BACKFILLED TO FINISHED GRADE PRIOR TO DISCHARGING ANY WATER ON THE GROUND.
3. AFTER BACTERIOLOGICAL CLEARANCE IS RECEIVED, THE CONTRACTOR SHALL TURN CORPORATION STOP OFF, REMOVE TUBING AND PLUG COPORATION STOP WITH BRASS PLUG/CAP.
4. SERVICE SADDLE SHALL BE PER QUALIFIED PRODUCTS LIST. NO DIRECT TAPS



**MINIMUM CONSTRUCTION STANDARDS FOR  
ST. LUCIE WEST SERVICES DISTRICT**  
450 SW UTILITY DRIVE,  
PORT SAINT LUCIE, FL 34986  
PHONE: (772) 340-0220

**WATER SAMPLING POINT**

<b>DETAIL: SLW-09</b>
<b>DATE: 03/2020</b>
<b>SCALE: N.T.S.</b>
<b>SHEET: 1 OF 1</b>