



NOTES:

1. THE VALVE BOX AND COLLAR SHALL BE IN ACCORDANCE WITH STANDARD DETAIL SLWG-01.
2. TAPPING SLEEVE SHALL BE PER QUALIFIED PRODUCTS LIST.
3. THRUST BLOCKS MAY BE REQUIRED AT THE SLWSD'S DIRECTION. (CASE BY CASE)
4. NO TAP WILL BE ALLOWED CLOSER THAN 5 FEET FROM ANY JOINT, FITTING OR EXISTING TAP ALONG THE MAIN.



**MINIMUM CONSTRUCTION STANDARDS FOR
ST. LUCIE WEST SERVICES DISTRICT
450 SW UTILITY DRIVE,
PORT SAINT LUCIE, FL 34986
PHONE: (772) 340-0220**

WET TAP ASSEMBLY

| |
|------------------------|
| DETAIL: SLWG-03 |
| DATE: 03/2020 |
| SCALE: N.T.S. |
| SHEET: 1 OF 1 |