

## MINIMUM SEPARATION BETWEEN SLWSD FACILITIES AND OTHER UTILITIES

OTHER PIPE	HORIZONTAL SEPARATION	CROSSINGS (1)	JOINT SPACING @ CROSSINGS (FULL JOINT CENTERED)
<p><b>GRAVITY OR PRESSURE SANITARY SEWER, SANITARY SEWER FORCE MAIN, RECLAIMED WATER (3), VACUUM SANITARY SERVICE</b></p>	<p style="text-align: center;">10' MINIMUM</p>	<p style="text-align: center;">18' MINIMUM</p>	<p style="text-align: center;">6' MINIMUM</p>
<p><b>ALL OTHER FACILITIES, INCLUDING BUT NOT LIMITED TO: STORM SEWER, STORMWATER FORCE MAIN, RECLAIMED WATER (2), TELEPHONE, CABLE TV, POWER, ETC.</b></p>	<p style="text-align: center;">5' MINIMUM</p>	<p style="text-align: center;">18' MINIMUM</p>	<p style="text-align: center;">3' MINIMUM</p>
<p><b>ON-SITE SEWAGE TREATMENT AND DISPOSAL SYSTEM</b></p>	<p>10' MINIMUM</p>	<p>-----</p>	<p>-----</p>

**NOTES:**

1. WATER MAIN SHOULD CROSS OVER OTHER PIPE. WHEN WATER MAIN MUST BE BELOW OTHER PIPE, THE MINIMUM SEPARATION IS 18".
2. RECLAIMED WATER REGULATED UNDER PART III OF CHAPTER 62-610, F.A.C.
3. RECLAIMED WATER NOT REGULATED UNDER PART III OF CHAPTER 62-610, F.A.C.
4. A SLWSD FACILITY INCLUDES MAINS AND STRUCTURES FOR POTABLE WATER, WASTEWATER AND RECLAIMED WATER. WHEN A GRAVITY SEWER IS TO BE INSTALLED PARALLEL TO A DRAINAGE PIPE GREATER THAN 15" DIAMETER A MINIMUM HORIZONTAL SEPARATION OF 15' SHALL BE MAINTAINED; GREATER SEPARATION MAY BE REQUIRED BY SLWSD FOR PIPES LARGER THAN 24" IN DIAMETER. WHEN A FORCE MAIN OR RECLAIMED WATER MAIN IS TO BE INSTALLED PARALLEL TO A DRAINAGE PIPE A MINIMUM HORIZONTAL SEPARATION OF 8' SHALL BE MAINTAINED; A GREATER SEPARATION MAY BE REQUIRED FOR DRAINAGE PIPES LARGER THAN 48" IN DIAMETER.



MINIMUM CONSTRUCTION STANDARDS FOR  
ST. LUCIE WEST SERVICES DISTRICT  
450 SW UTILITY DRIVE,  
PORT SAINT LUCIE, FL 34986  
PHONE: (772) 340-0220

## STANDARD SEPARATION REQUIREMENTS

<b>DETAIL: SLWG-04</b>
<b>DATE: 03/2020</b>
<b>SCALE: N.T.S.</b>
<b>SHEET: 1 OF 1</b>