



NOTES:

1. AN ACCESS BOX AND COVER ON THE QUALIFIED PRODUCT LIST SHALL BE USED.
2. CLEANOUT ASSEMBLY SHALL BE INSTALLED AT A MAXIMUM 75' INTERVALS AND AT TERMINAL POINT OF THE SLWSD RESPONSIBILITY. THE LOCATION SHALL BE IN ACCORDANCE WITH THE SLWSD UTILITY STANDARDS. "POINT OF SERVICE"
3. MARKER BALL SHALL BE STRAPPED TO THE ELBOW.



**MINIMUM CONSTRUCTION STANDARDS FOR
ST. LUCIE WEST SERVICES DISTRICT**
450 SW UTILITY DRIVE,
PORT SAINT LUCIE, FL 34986
PHONE: (772) 340-0220

SANITARY SEWER CLEANOUT

DETAIL: SLWS-01
DATE: 03/2020
SCALE: N.T.S.
SHEET: 1 OF 1