



PLAN VIEW

NOTES:

1. THE ENGINEER-OF-RECORD SHALL SUBMIT TO SLWSD THE SHOP DRAWINGS FOR EACH STRUCTURE, PROVIDING THE DIAMETER OF EACH PIPE, INVERT ELEVATION OF EACH PIPE, RIM ELEVATION AND THE NUMBER OF DEGREES BETWEEN PIPES.
2. MANHOLE INTERIOR SHALL BE LINED UTILIZING A CORROSION BARRIER SYSTEM ON THE QUALIFIED PRODUCTS LIST (QPL).
3. MANHOLE EXTERIOR SHALL BE COATED WITH A PRIMER AND TWO COATS OF A WATER BASED EPOXY 3-5 MILS EACH PER THE SLWSD STANDARDS. APPLICATION SHALL BE IN ACCORDANCE WITH THE MANUFACTURER'S SPECIFICATION.



MINIMUM CONSTRUCTION STANDARDS FOR
ST. LUCIE WEST SERVICES DISTRICT
450 SW UTILITY DRIVE,
PORT SAINT LUCIE, FL 34986
PHONE: (772) 340-0220

**INVERT FLOW CHANNELS
FOR
MANHOLES**

DETAIL: SLWS-07
DATE: 03/2020
SCALE: N.T.S.
SHEET: 1 OF 1