



NOTES:

1. THE MANHOLE SHALL BE CONSTRUCTED AS SHOWN IN THIS DETAIL WHERE THE DROP IN INVERT EXCEEDS 0.1' BUT IS LESS THAN 2'. FOR DROPS 2' OR GREATER A DROP CONNECTION (DETAIL SLWS-09) SHALL BE USED.
2. ALL DETAILS AND SPECIFICATIONS FOR "STANDARD PRECAST MANHOLE" (DETAIL SLWS-05) ARE APPLICABLE.
3. ALL MATERIALS AND COMPONENTS USED SHALL BE PER THE QUALIFIED PRODUCTS LIST.



MINIMUM CONSTRUCTION STANDARDS FOR
 ST. LUCIE WEST SERVICES DISTRICT
 450 SW UTILITY DRIVE,
 PORT SAINT LUCIE, FL 34986
 PHONE: (772) 340-0220

**STANDARD PRECAST MANHOLE
 (DROP)**

DETAIL: SLWS-08
DATE: 03/2020
SCALE: N.T.S.
SHEET: 1 OF 1