



NOTES:

1. LIFT STATION DESIGNATION WILL BE ASSIGNED BY SLWSD.
2. THE SIGN SHALL BE 1/8" ALUMINUM WITH REFLECTIVE WHITE BACKGROUND AND BLACK LETTERING.
3. THE SIGN SHALL BE MOUNTED ON LIFT STATION GATE OR FENCE A MINIMUM 48" FROM BOTTOM OF FENCE AND SHALL BE VISIBLE FROM STREET. THE SIGN SHALL BE PERMANENTLY ATTACHED TO THE FENCE.



MINIMUM CONSTRUCTION STANDARDS FOR
 ST. LUCIE WEST SERVICES DISTRICT
 450 SW UTILITY DRIVE,
 PORT SAINT LUCIE, FL 34986
 PHONE: (772) 340-0220

LIFT STATION SIGNAGE

DETAIL: SLWS-22
DATE: 03/2020
SCALE: N.T.S.
SHEET: 1 OF 1